

Alexandra Sykes

From: Patrick Richards
Sent: Tuesday, January 13, 2026 1:19 PM
To: Elisabeth Parker
Cc: Alexandra Sykes; Bub Fournier
Subject: Re: Proposal for 58 Swan Lake Avenue

Follow Up Flag: Follow up
Flag Status: Flagged

Good afternoon,

My apologies for the delay. I was looking into the distance from the nearest Fire Hydrant on the corner of Mill Lane Rd. It looks like that is another 150' from your proposed road. If possible, a fire hydrant at the beginning of the proposed road would be good. Other than that, I have no concerns at this time.

Patrick Richards
Fire Chief/Ambulance Director
City of Belfast, ME
(207)338 3362

From: Elisabeth Parker <elisabeth@terrafirmaengineering.com>
Sent: Tuesday, January 13, 2026 12:58 PM
To: Patrick Richards <firechief@cityofbelfast.org>
Subject: Re: Proposal for 58 Swan Lake Avenue

Hi Patrick,

I just wanted to follow up on this and see if you have any concerns?

Thanks,
Elisabeth

On Thu, Jan 8, 2026 at 9:59 AM Elisabeth Parker <elisabeth@terrafirmaengineering.com> wrote:
It's approximately 520'.

Thanks,
Elisabeth

On Wed, Jan 7, 2026 at 4:09 PM Patrick Richards <firechief@cityofbelfast.org> wrote:
Good afternoon,

Thank you for the plans. How long is the road from Swan Lake Ave to the end?

Thanks

Patrick Richards
Fire Chief/Ambulance Director

City of Belfast, ME
(207)338 3362

From: Elisabeth Parker <elisabeth@terrafirmaengineering.com>

Sent: Wednesday, January 7, 2026 1:27 PM

To: Patrick Richards <firechief@cityofbelfast.org>

Subject: Proposal for 58 Swan Lake Avenue

Hello Patrick,

I spoke to Alexandra Skyes about a project we are working on that includes 8 new units at 58 Swan Lake Avenue, and she asked me to check in with you. I attached a draft of the plan to this email. Please let me know if you have any questions or concerns.

Thanks,
Elisabeth

--